

BXUV.X518



Design/System/Construction/Assembly Usage Disclaimer

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Certified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered Certified.

BXUV - Fire Resistance Ratings - ANSI/UL 263 Certified for United States

BXUV7 - Fire Resistance Ratings - CAN/ULC-S101 Certified for Canada


See General Information for Fire-resistance Ratings - ANSI/UL 263 Certified for United States
Design Criteria and Allowable Variances

See General Information for Fire Resistance Ratings - CAN/ULC-S101 Certified for Canada
Design Criteria and Allowable Variances

Design No. X518

Rating — 2 Hr.

*** Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.**



1. **Steel Studs** — 1-5/8 in. wide with leg dimensions of 1-5/16 and 1-7/16 in. with a 1/4 in. folded flange in legs, fabricated from 25 MSG galv steel. Steel stud cut 1/2 in. less in length than assembly height.

2. **Gypsum Board*** — Two layers of 1/2 in. thick gypsum board.

AMERICAN GYPSUM CO — Types AG-C.

CABOT MANUFACTURING ULC — Type C.

CERTAINTED GYPSUM INC — Type C

CGC INC — Types C, IP-X2, IPC-AR.

CERTAINTED GYPSUM INC — Type LGFC-C/A.

GEORGIA-PACIFIC GYPSUM L L C — Types 5, DAPC, TG-C.

NATIONAL GYPSUM CO — Types -eXP-C, FSK-C, FSW-C.

PABCO BUILDING PRODUCTS L L C, DBA PABCO GYPSUM — Type PG-C.

PANEL REY S A — Type PRC

THAI GYPSUM PRODUCTS PCL — Type C.

UNITED STATES GYPSUM CO — Types C, IP-X2, IPC-AR.

USG BORAL DRYWALL SFZ LLC — Type C

USG MEXICO S A DE C V — Types C, IP-X2, IPC-AR.

2A. Gypsum Board* — (Not Shown)- As an alternate to Item 2. Two layers of 5/8 in. thick gypsum board.

CGC INC — Type ULIX

UNITED STATES GYPSUM CO — Type ULIX

2B. Gypsum Board* — (As an alternate to Item 2, For use with Item 5A) — 1/2 in. thick, two layers.

CERTAINTED GYPSUM INC — Type C

3. Screws — 1 in. long self-drilling, self-tapping screws, spaced vertically 24 in. on centers, except on the outer layer of wallboard on the flanges, which are spaced on 12 in. centers.

4. Screws — 1-5/8 in. long self-drilling, self-tapping screws spaced vertically 12 in. OC.

5. Corner Beads — No. 28 MSG galv steel, 1-1/8 in. legs. Attached to wallboard with 4d by 1-3/8 in. nails spaced 12 in. OC at each leg.

5A. Corner Bead* — (As an alternate to Item 5, For use with Item 2B) — 0.058 in. thick at shoulder thickness, 1-7/8 in. legs, attached to gypsum board using all-purpose ready mix joint compound.

CERTAINTED CORP — Type NC

6. Joint Compound — 1/16 in. thick. As an option, nom 3/32 in. thick gypsum veneer plaster may be applied to the entire surface of Classified veneer baseboard.

7. Steel Column — Min size of column, W10 x 49, with outside dimensions of 10 x 10 in. with a flange thickness of 9/16 in., a web thickness of 5/16 in., and a cross-sectional area of 14.4 sq in.

*** Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.**

La presencia del nombre de una empresa o producto en esta base de datos no garantiza por sí misma que los productos así identificados hayan sido fabricados bajo el servicio de seguimiento de UL. Solo aquellos productos que lleven la marca UL deben considerarse como certificados y garantizados bajo el servicio de seguimiento de UL. Busque siempre la marca en el producto.

UL permite la reproducción del material contenido en el directorio de certificación en línea sujeta a las siguientes condiciones: 1. La información de la guía, las ensamblajes, las construcciones, los diseños, los sistemas y/o certificaciones (archivos) deben presentarse en su totalidad y de forma no engañosa, sin ninguna manipulación en los datos (o dibujos). 2. Debe aparecer la declaración "Reimpreso desde el directorio de certificaciones en línea con permiso de UL" junto al material extraído. Además, el material reimpreso debe incluir una nota de derechos de autor en el siguiente formato: "© 2021 UL LLC"